

CERTIFICATE

No. U8V 06 01 21477 004

**Holder of Certificate:** Westcor Corporation560 Oakmead Parkway
Sunnyvale CA 94085-4022
USA**Production Facility(ies):** 21477**Certification Mark:****Product:** Power supply
AC-DC / DC-DC Power Supply**Model(s):** PFC Front end Model FE 375**Parameters:**
Rated Input Voltage: 115-230 V AC or 300 V DC
Rated Frequency: 47-500 Hz
Rated Input Current: 12 A**Tested according to:** CAN/CSA-C22.2 No. 60950-1-03
UL 60950-1:2003
EN 60950-1:2001

The product was voluntarily tested according to the relevant safety requirements and mentioned properties. It can be marked with the certification mark shown above. See also notes overleaf.

Test report no.: 090-504519-000**Date,** 2006-02-01

Page 1 of 2



Attachment to Certificate Number U8V 06 01 21477 004

Company: Westcor Corporation
560 Oakmead Parkway
Sunnyvale, CA 94085-4022 USA

**License Conditions:**

1. The FE 375 is designed for building-in and must be installed in accordance with the manufacturer's specifications.
2. The Output of the FE375 is rated 375 Vdc, 1500 W Max. See design guide for specific Output Power vs. Input Voltage ratings.
3. The FE375 has been evaluated for a Max Ambient of 55 °C.
4. The FE375 requires a 12A external fuse in the end use application. UL Listed Bussmann ABC-12 or equivalent.

AR
2/1/06

A circular blue seal for TÜV Product Service Danvers. The outer ring contains the text 'TÜV PRODUCT SERVICE' at the top and 'DANVERS' at the bottom, separated by two stars. The center of the seal features the 'TÜV' logo and the words 'PRODUCT SERVICE' below it.